

NOTES:

- 1. AIR RELEASE RISER AND PVC PIPE HOUSING SHALL BE PLACED AND MAINTAINED IN VERTICAL POSITION.
- 2. METALLIC THREADS TO BE COATED WITH BITUMASTIC COATING.
- 3. FOR MANHOLE/VALVE BOX IN GRASS AREAS, SEE SS 21.0 SHEET 1 OF 1.

TYPE "A" MANHOLE	SS 4.0	
ITEM	CROSS REF.	SPEC. REF.

MIAMI-DADE COUNTY Delivering Excellence Every Day				
WATER & SEWER DEPARTMENT				

<u>ISSUE DATE</u>	<u>APPROVED BY</u>
10/16/2009	V.F.C.

STANDARD DETAIL

AIR RELEASE VALVE ASSEMBLY IN PAVED AREAS FOR SEWAGE FORCE MAINS SS 11.0 SHEET 1 OF 2